



Pride in Service with Integrity

BROWARD SHERIFF'S OFFICE DEPARTMENT OF FIRE RESCUE AND EMERGENCY SERVICES



SAFETY ADVISORY UNSAFE STRUCTURE

SA 08-07

SAFETY ADVISORY

CAD ZONE: 27G GRID # 1632
DISTRICT: District 27 West Park
DATE: 12/4/2008
LOCATION: Private Residence
3001 SW 34 Avenue
West Park, FL 33311



This is a detached garage in a residential neighborhood that was well involved in fire. The Building department has tagged this garage unsafe. There are signs that transient trespassing is occurring on this property.

The residence is Red Tagged and Fire Line taped to identify to anyone trespassing that the building is unsafe.

Defensive Tactics should be deployed due to significant charring to the truss members from the past fire. Be aware of the pool in the front of the garage this will present a hazard to any emergency operations at this location. If conducting rescue efforts extreme caution is encouraged due to the unsafe condition of the structure.

Fire Marshal's Bureau
2601 West Broward Boulevard
Fort Lauderdale, FL 33312

Phone: 954-831-8210
Fax: 954-831-8218
E-mail: FMO_Issues@sheriff.org

