



*Pride in Service with Integrity*

**BROWARD SHERIFF'S OFFICE  
DEPARTMENT OF FIRE RESCUE  
AND EMERGENCY SERVICES**



# SAFETY ADVISORY UNSAFE STRUCTURE

**SA 08-08**

**SAFETY  
ADVISORY**

CAD ZONE: 27B GRID # 1592  
DISTRICT: 27 Pembroke Park  
DATE: 12/9/2008  
LOCATION: Pembroke Park Warehouses  
3120-3140 Pembroke Road  
Pembroke Park, FL. 33009



**This Safety Advisory pertains to the warehouse complex located just east of Park Road on Pembroke Road. The Fire Marshal's Bureau has begun joint inspections of this location with the Pembroke Park Building Official. Several Bays have been found with people living in the bays and/or unsafe structures built within the bays (false ceilings which are second floors). These unsafe structures built within the bays create a potential collapse hazard for Fire Fighters who may have to enter the bays under fire conditions. The Pembroke Park Building Official has cited the property owner and red tagged the respective bays as unsafe structures, including the disconnection of electrical service where applicable. Emergency responders must use caution when responding to this property.**

Fire Marshal's Bureau  
2601 West Broward Boulevard  
Fort Lauderdale, FL 33312

Phone: 954-831-8210

Fax: 954-831-8218

E-mail: [FMO\\_Issues@sheriff.org](mailto:FMO_Issues@sheriff.org)

