



Pride in Service with Integrity

**BROWARD SHERIFF'S OFFICE
DEPARTMENT OF FIRE RESCUE
AND EMERGENCY SERVICES**



SAFETY WARNING

Unsafe Structure

SW 11-01

**SAFETY
WARNING**

Fire Marshal's Bureau
2601 West Broward Boulevard
Fort Lauderdale, FL 33312

Phone: 954-831-8210

Fax: 954-831-8218

E-mail: FMO_Issues@sheriff.org

CAD ZONE: 27B GRID # 1593
DISTRICT: 27 Pembroke Park
DATE: 2/11/2011
LOCATION: M E Enterprises
2000 SW 30 Ave,
Pembroke Park, FL



The Broward Sheriff's Office Fire Marshal's Bureau has issued an immediate corrective action order for dangerous amounts of storage of combustible materials. The storage heights and amounts stored are creating an imminent threat to life. There are Non-permitted interior build outs that could become compromised in fire conditions. Corrective actions have started but are not compliant at this time. Extreme Caution and Defensive Tactics should be deployed under fire conditions.